

# Display energy certificate (DEC)



HM Government

The Regis School  
Swimming Pool  
Westloats Lane  
Bognor Regis  
PO21 5LH

Operational rating

# A

Certificate number: 2595-1950-0793-1392-4805

Valid until: 29 September 2031

Total useful floor area: 656 square metres

## Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO<sub>2</sub>) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	<b>A</b>	15   <b>A</b>	
26-50	<b>B</b>		
51-75	<b>C</b>		
76-100	<b>D</b>		100
101-125	<b>E</b>		
126-150	<b>F</b>		
150+	<b>G</b>		

## Previous operational ratings

Date	Operational rating
September 2021	15   <b>A</b>

## Total carbon dioxide (CO<sub>2</sub>) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO<sub>2</sub>.

Date	Electricity	Heating	Renewables
September 2021	22	14	0

## Assessment details

Assessor's name	Alastair Humphries-Cuff
Employer/Trading name	ESOS Energy Ltd
Employer/Trading address	5th Floor Castlemead, Lower Castle Street, Bristol, BS1 3AG
Assessor's declaration	Not related to the occupier.
Accreditation scheme	CIBSE Certification Limited
Issue date	11 October 2021
Nominated date	30 September 2021

## This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m <sup>2</sup> /year)	59.91	112.91
Typical energy use (kWh/m <sup>2</sup> /year)	245	1152.11
Energy from renewables	0%	0%